

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No 6911-0026:268 Page 1 of 1

CATEGORY: Voice Communication System Control Unit

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN: Model DIRECTONE 3300 series. voice communication system. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

PN976097	Interface Module
PN4280-068	End of the Line Resistor
PN5130-069-11	Supervision & Audio Switching Module
PN5290-026/027	8 Amp Power Supply Assembly
C4280-852	Remote Telephone Jack
D5130-069-09/17	Control Board
D5130-069-07	Trouble Board
D5130-071-09	Speaker Supervision Board
D5200-260/261	Tape deck
D5200-212	AC/DC power inverter
D5200-0963/450	Power Supply
D5290-021	Audio Power Supply
D5200-214	Automatic Zone Select Module
D5200-001	Master Multi Zone Module
D5200-0193	Switch Module
D5200-191/255/256	Communication Module
D5200-031	Relay Module
D5200-437	Digitized Audio Panel
D5290-013, 015, 016, 017, 018, 019, 020	Single Channel Amplifier Module
D4280-930	Audio Attenuator
D5290-030	Indicating Device Circuit Module
5130-071-08	Signal Generator Logic Card
5290-003/005	Signal Generator
5130-073-06	Chime Tone Generator Module
5130-073-07	Horn Tone Generator Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a voice communication system control unit for use with separately listed compatible fire alarm control units.

NOTE: Formerly 7170-0077:044, 6911-0077:044 and 6911-1493:106

*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 13, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**